

# **Insulation Work – Protecting Buildings – and Protecting Yourself Fatality File**

## **Worker Dies of Head Injuries after Falling from Ladder**

At approximately 7:45 a.m. on April 3, 2014, Employee #1, an insulation worker employed by a plastering, drywall, and insulation company, was working at a school building that was being newly constructed. He was in corridor K of B wing, standing on a 10-foot stepladder, Werner Fiberglass Model 6210, Part Number 100515-35, and using a brush to apply Design Polymeric Water Based Vapor Barrier DP3040 from a two-gallon bucket. This was one step in the process of installing and sealing HVAC duct work insulation inside the building. Employee #1 fell from the ladder. He was found lying on the concrete floor, moaning and incoherent.

Emergency services were called, and Employee #1 was airlifted to Palmetto Health Richland Hospital, where he was admitted and treated for head injuries. Employee #1 died at the hospital the following day, April 4, 2014. This event was investigated by South Carolina OSHA. The investigation determined that Employee #1 weighed approximately 165 pounds and was 5 feet 7 inches tall.

The stepladder was less than six months old and had no visible defects. It was rated for 300 pounds. The ladder was situated on a level concrete floor when Employee #1 fell. The highest part of the HVAC duct work was approximately 12 feet 6 inches above the floor, and the lowest part was approximately 11 feet above the floor.

**Source:** [stopconstructionfalls.com](http://stopconstructionfalls.com)